

Schena, Cristeen

From: Aram Varjabedian <avarjabedian@woodardcurran.com>
Sent: Wednesday, March 07, 2018 7:30 PM
To: Aram Varjabedian; tberardinelli@town.hull.ma.us; Bill Boornazian; david.burns (david.burns@state.ma.us); Jim Dow; Frank Cavaleri; jstruzziery@town.hull.ma.us; jsullivan (jsullivan@town.hull.ma.us); Kate Roosa; kbornheim (kbornheim@town.hull.ma.us); Krahforst, Chris (ckrahforst@town.hull.ma.us); Lemnios, Philip (plemnios@town.hull.ma.us); coconnor@town.hull.ma.us; Robert Scott; Turin, David
Subject: Hull, MA - MA0101231 - SSO Notification Report March 3, 2018
Attachments: final_report_Hull_SSO_030318_MA0101231.pdf

Good evening all:

Attached please find the Sanitary System Overflow Report for the Hull WPCF that occurred on March 3rd as a result of the winter storm and strong tidal surges that significantly impacted the town and the wastewater facility. The very high astronomical tides in conjunction with the storm surge and the rainfall that occurred around the time of high tide, led to influent flows to the WPCF that were very high, and the wastewater could not exit the facility via the outfall pipe.

I apologize that the initial notification, did not include the entire contact list. With the high plant and pump station flows over the past number of days, the notification was made to the EPA and DEP on 3/2/18, as there was the likelihood of flow diversion or overflow, but at that time, nothing had occurred. Subsequent emails were made to those agencies and are attached.

Should you need any additional information, please contact me.

Sincerely,

Aram

Aram Varjabedian
Plant Manager
Hull Wastewater Treatment Facility
1111 Nantasket Avenue | Hull, MA 02045
Phone 781.925.0906 | Fax 781.925.3056 | Cell 339.214.8334
www.woodardcurran.com



COMMITMENT & INTEGRITY DRIVE RESULTS